

2013-024 Greywater from washing machine, owner hired plumber to fix cross-connection

2013-025 Process water from indoor agriculture operation discharged to creek when pump failed, Manager and staff working to repair pump.

2013-026 Carwash waste water flowing into street gutter, pipe connecting to the drain was clogged. That wash bay was shut down until a plumber removed the clog.

2013-027 Illegal grading across creek, referred to CDFW

2013-028 Well cistern clean out resulted in discharge of sediment laden water to storm drain and creek. Sediment was cleaned out of the street gutters and future discharge water was directed onto landscaping.

2013-029 Pet waste thrown over back fence onto Flood Control access road. Educated homeowner about pet waste and water quality and requested removal of waste.

2013-030 Trash, debris and human waste discovered in creek, contractor hired to clean the site.

2013-031 Soapy wash water entering creek from drainage near fire station. Firefighters were asked to wash vehicles on the grass and dispose of wash water in sanitary sewer or landscaping.

2013-032 Couch in creek, contractor cleaned the site.

2013-033 Broken computer monitor in creek, contractor cleaned site.

2013-034 Trash in creek, contractor cleaned site.

2014-001 Diatomaceous earth discharged to creek, mining company was notified, discharges continued, notified the Regional Water Quality Control Board.

2014-004 Pool water discharged through garden hose into creek. Notified homeowner who stopped the discharge and removed the hose from the creek.

2014-005 Horse manure piled on banks of creek, referred to Resource Recovery, owners agreed to keep manure away from the creek.

2014-006 Oil in water near Carpinteria Pier, Environmental Health and CDFW responded to the site, no fueling occurs at Carpinteria Pier, appeared to be from natural seepage.

2014-007 Pool water discharge, educated owner about chlorinated water and water quality.

2014-008 Five gallon bucket of used oil discovered on the beach, removal and proper disposal by Public Works staff

- 2014-009 Gravel from landscaping construction washed into street following heavy rain, referred to Road Encroachment Permit Inspector, contacted homeowner and requested clean-up.
- 2014-010 Trash in creek, contractor cleaned site.
- 2014-011 Debris from nursery operation in creek, contacted owner who had staff clean up.
- 2014-012 Nursery greenwaste dumped in creek, owner notified and removed debris.
- 2014-013 Greenwaste dumped in creek, home owner notified and removed debris.
- 2014-014 Sediment from nursery blocking drainage culvert, Manager notified, agreed to have staff clean out the drain more frequently.
- 2014-015 Greywater with sulfur smell in the creek, Sanitary District surveyed sewer lines, no leaks found.
- 2014-016 Concrete truck washout onto unpaved alleyway, referred to Road Encroachment Permit Inspector.
- 2014-017 Process water from indoor agriculture operation discharged to creek when pump failed, required owner to install redundant system or increase capacity of existing system.
- 2014-018 RV greywater discharged to gutter, educated owner about water quality and legal greywater disposal locations
- 2014-019 Runoff from overwatering, water sample bacteria levels normal, forwarded to Water District who issued notice of violation.